

## Exhaust Emission Data Sheet C125 N6

## 60 Hz Spark Ignited Generator Set EPA Emissions

**Engine Information:** 

Model:QSJ8.9GBore:4.49 in. (114.1 mm)Type:4 Cycle, In-line, 6 CylinderStroke:5.69 in. (144.5 mm)Aspiration:Turbocharged and aftercooledDisplacement:543 cu. in. (8.9 liters)

Compression Ratio: 9.7:1

Emission Control Device: Electronic Air/Fuel Ratio Control and Closed-Loop Breather System

	Natural Gas
PERFORMANCE DATA	Standby
BHP @ 1800 RPM (60 Hz)	205
Fuel Consumption (SCFH)	1660.9
Air to Fuel Ratio	24.0
Exhaust Gas Flow (CFM)	1200
Exhaust Gas Temperature (°F)	1197
EXHAUST EMISSION DATA	
HC (Total Unburned Hydrocarbons)*	247
NOx (Oxides of Nitrogen as NO <sub>2</sub> )	203
CO (Carbon Monoxide)	420
	Values are ppmvd
HC (Total Unburned Hydrocarbons)*	0.60
NOx (Oxides of Nitrogen as NO <sub>2</sub> )	1.00
CO (Carbon Monoxide)	1.90
Values are Grams per HP-Hour	

<sup>\*</sup>HC includes all NMHC, VOC, POC, and ROC constituents (Non-Methane HC, Volatile Organic Compounds, Precursor Organic Compounds, and Reactive Organic Compounds)

## **TEST CONDITIONS**

Data was recorded during steady-state rated engine speed ( $\pm$  25 RPM) with full load ( $\pm$ 2%). Pressures, temperatures, and emission rates were stabilized.

Fuel Specification:

Natural Gas: Dry gas as received from Supplier (1000 BTU/SCF).

Fuel Temperature: 60 ± 9 °F at Flow Transmitter

Fuel Pressure: 14.73PSIA ± 0.5 PSIA at Flow Transmitter

Intake Air Temperature:  $77 \pm 9$  °F at inlet Barometric Pressure: 29.92 in. Hg  $\pm$  1 in. Hg

Humidity: NOx measurement corrected to 75 grains H2O/lb dry air

The NOx, HC, and CO emission data tabulated here were from a single engine under the test conditions shown above. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limit, or with improper maintenance, may results in elevated emission levels.

Data and Specifications Subject to Change Without Notice