


REV	DATE	REVISION	BY	APP
-	6-15-11	NEW DRAWING [90714-3]	CRS	

- LEGEND**
- BR BRIDGE RECTIFIER
 - C COIL
 - CE TRANSFER COIL (EMERGENCY TRANSFER)
 - CN TRANSFER COIL (NORMAL TRANSFER)
 - K4 NORMAL RELAY CONTACTS
 - K5 EMERGENCY RELAY CONTACTS
 - LSE LIMITS SWITCH EMERGENCY CONTACTS
 - LSN LIMIT SWITCH NORMAL CONTACTS
 - P(#) CONNECTOR



- NOTE:**
1. RBUS & LOAD CONTROL CONTACT RATED 30 VOLT, 1 AMP. WIRING PROVIDED BY OTHERS.
 2. CONTACTOR SHOWN IN NORMAL WITH NO POWER APPLIED.

- NOTE:**
- 1) THE TRANSFER SWITCH AND CONTROLS ARE SHOWN DE-ENERGIZED WITH THE TRANSFER SWITCH CONTACTS CLOSED ON THE NORMAL SOURCE.
 - 2) REFER TO THE TRANSFER SWITCH AND GENERATOR OPERATION AND INSTALLATION MANUALS PRIOR TO INSTALLATION.
 - 3) SERVICE DISCONNECT CIRCUIT BREAKERS ARE:
 100A, 80% RATED SQUARE D QOM1
 200A, 80% RATED SQUARE D QOM2
 400A T-M, 80% RATED SIEMENS NJJ2B400K

MODEL RXT SERVICE ENTRANCE 100-400A, 1φ FOR WIRING DIAGRAM SEE GM80665

KOHLER CO. POWER SYSTEMS, FORT LEE, NJ 07024 U.S.A. <small>THIS DRAWING IS UNLESS AND UNLESS OTHERWISE SPECIFIED IS THE PROPERTY AND SHALL REMAIN THE PROPERTY OF KOHLER CO. NO PART OF THIS DRAWING IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.</small>	
APPROVALS CRS 6-15-11 MTL 6-15-11 MTL 6-15-11	DATE 6-15-11 6-15-11 6-15-11
SCALE E	SHEET NO. 1-1
DRAWING NO. GM80666	REV. NO. D